

2017 Consumer Confidence Report Data MEQUON WATER UTILITY, PWS ID: 24601126

Water System Information

If you would like to know more about the information contained in this report, please contact James Voigt at (414) 559-8656.

Purchased Water Our water system purchases water from NORTH SHORE WATER COMMISSION primarily for the Village of Bayside customers. In addition to the detected contaminants listed below, test results from NORTH SHORE WATER COMMISSION can be found at <https://northshorewc.github.io/ccr2017/>

Our water system purchases water from MILWAUKEE WATERWORKS primarily for our City of Mequon and Village of Thiensville customers. In addition to the detected contaminants listed below, test results from MILWAUKEE WATERWORKS can be found at https://www.ci.mequon.wi.us/sites/default/files/fileattachments/sewer_amp_water_utilities/page/6421/milwaukee_water_works_consumer_confidence_report_2017.pdf

Opportunity for input on decisions affecting your water quality

Participate in decisions that affect drinking water quality at meetings of the City of Mequon Water Commission, which meets at Mequon City Hall, 11333 N Cedarburg Rd, Mequon, WI 53092, and at meetings of the City of Mequon Common Council, 11333 N Cedarburg Rd, Mequon, WI 53092. The Water Commission and Common Council meetings vary. Please contact the City Clerk for a schedule at (262)236-2912, or visit <http://www.ci.mequon.wi.us>

Health Information

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's safe drinking water hotline (800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune systems disorders, some elderly, and infants can be particularly at risk from infections.

These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbial contaminants are available from the Environmental Protection Agency's safe drinking water hotline (800-426-4791).

Source(s) of Water

Source ID	Source	Depth (in feet)	Status
2	Groundwater	250	Permanently Abandoned as of 04/06/2017
7	Purchased Surface Water		Active
12	Purchased Surface Water		Active
13	Purchased Surface Water		Active
16	Groundwater	120	Permanently Abandoned as of 02/20/2018
17	Groundwater	120	Permanently Abandoned as of 02/06/2018

Purchased Water

PWS ID	PWS Name
24135155	NORTH SHORE WATER COMMISSION
24101000	MILWAUKEE WATERWORKS

To obtain a summary of the source water assessment please contact, James Voigt at (414) 559-8656.

Educational Information

The sources of drinking water, both tap water and bottled water, include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally- occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff and residential uses.

- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff and septic systems.
- Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water, which shall provide the same protection for public health.

Definitions

Term	Definition
AL	Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
Level 1 Assessment	A Level 1 assessment is a study of the water system to identify potential problems and determine, if possible, why total coliform bacteria have been found in our water system.
Level 2 Assessment	A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine, if possible, why an E. coli MCL violation has occurred or why total coliform bacteria have been found in our water system, or both, on multiple occasions.
MCL	Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
MCLG	Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
MFL	million fibers per liter
MRDL	Maximum residual disinfectant level: The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
MRDLG	Maximum residual disinfectant level goal: The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
mrem/year	millirems per year (a measure of radiation absorbed by the body)
NTU	Nephelometric Turbidity Units
pCi/l	picocuries per liter (a measure of radioactivity)
ppm	parts per million, or milligrams per liter (mg/l)
ppb	parts per billion, or micrograms per liter (ug/l)
ppt	parts per trillion, or nanograms per liter

Term	Definition
ppq	parts per quadrillion, or picograms per liter
TCR	Total Coliform Rule
TT	Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water.

Detected Contaminants

Your water was tested for many contaminants last year. We are allowed to monitor for some contaminants less frequently than once a year. The following tables list only those contaminants which were detected in your water. If a contaminant was detected last year, it will appear in the following tables without a sample date. If the contaminant was not monitored last year, but was detected within the last 5 years, it will appear in the tables below along with the sample date.

Disinfection Byproducts

Contaminant (units)	Site	MCL	MCLG	Level Found	Range	Sample Date (if prior to 2017)	Violation	Typical Source of Contaminant
HAA5 (ppb)	2	60	60	1	2		No	By-product of drinking water chlorination
TTHM (ppb)	2	80	0	2.9	11.8		No	By-product of drinking water chlorination
HAA5 (ppb)	R2	60	60	1	3		No	By-product of drinking water chlorination
TTHM (ppb)	R2	80	0	2.9	11.7		No	By-product of drinking water chlorination

Inorganic Contaminants

Contaminant (units)	Action Level	MCLG	90th Percentile Level Found	# of Results	Sample Date (if prior to 2017)	Violation	Typical Source of Contaminant
COPPER	AL=1.3	1.3	0.0760	0 of 30		No	Corrosion of

Contaminant (units)	Action Level	MCLG	90th Percentile Level Found	# of Results	Sample Date (if prior to 2017)	Violation	Typical Source of Contaminant
(ppm)				results were above the action level.			household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives
LEAD (ppb)	AL=15	0	1.60	1 of 30 results were above the action level.		No	Corrosion of household plumbing systems; Erosion of natural deposits

Other Drinking Water Regulations

One of our suppliers, Milwaukee Water Works, failed to report a deficiency on their 2016 CCR. On July 5th, 2016, Milwaukee Water Works received a notice of deficiency from the WI DNR that stated, “The paint on the outside of the storage facility looks inadequate and unclean with apparent corrosion.” The storage facility is not currently in use and has no associated health effects. An extension has been given by the DNR to complete repairs by December 31st, 2018. Milwaukee Water Works is on schedule to complete this item.

Health effects for any contaminants with MCL violations/Action Level Exceedances

Contaminant Health Effects

LEAD Infants and children who drink water containing lead in excess of the action level could experience delays in their physical or mental development. Children could show slight deficits in attention span and learning abilities. Adults who drink this water over many years could develop kidney problems or high blood pressure.

Additional Health Information

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Mequon Water Utility is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water

for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at www.epa.gov/safewater/lead.

Purchased Water

Our water system purchases water from NORTH SHORE WATER COMMISSION. In addition to the detected contaminants listed above, these are the results from NORTH SHORE WATER COMMISSION: <https://northshorewc.github.io/ccr2017/>

Our water system purchases water from MILWAUKEE WATERWORKS. In addition to the detected contaminants listed above, these are the results from MILWAUKEE WATERWORKS: https://www.ci.mequon.wi.us/sites/default/files/fileattachments/sewer_amp_water_utilities/page/6421/milwaukee_water_works_consumer_confidence_report_2017.pdf