



## 2015 Consumer Confidence Report

The U.S. Environmental Protection Agency (EPA) and Wisconsin Department of Natural Resources (DNR) require drinking water utilities to provide an annual Consumer Confidence Report to inform you of the source and quality of your drinking water, compliance and detected contaminants, and results from treating and monitoring water January 1 – December 31, 2015.

### Important Information

This report contains important information about your drinking water. Translate it, or speak with someone who understands it.

### Información Importante para nuestros clientes que hablan español

Este informe contiene información muy importante sobre su agua de beber. Tradúzcalo o hable con alguien que lo entienda bien.

### Item 1: Water System Information

If you have questions about this report, please call a Water Quality Representative at the Mequon Water Utility, (262) 236-8150.

Participate in decisions that affect drinking water quality at meetings of the City of Mequon Water Commission, which meets at Mequon City Hall, 11333 N Cedarburg Rd, Mequon, WI 53092, and at meetings of the City of Mequon Common Council, 11333 N Cedarburg Rd, Mequon, WI 53092. The Water Commission and Common Council meetings vary. Please contact the City Clerk for a schedule at (262)236-2912, or visit <http://www.ci.mequon.wi.us>

### Item 2: Source of Water

Mequon Water Utility is a consecutive system of the Milwaukee Water Works. The Milwaukee Water Works water source is surface water from Lake Michigan.

### Item 3: Definitions

<	"less than" or not detected
AL	Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirement that a water system must follow. Action Levels are reported at the 90 <sup>th</sup> percentile for homes at greatest risk.
Haloacetic Acids	HAA5: Monochloroacetic acid, dichloroacetic acid, trichloroacetic acid, monobromoacetic acid, dibromoacetic acid, tribromoacetic acid, bromochloroacetic acid, dibromochloroacetic acid, and bromodichloroacetic acid.
HA	Health Advisory: An estimate of acceptable drinking water levels for a chemical substance based on health effects information; a Health Advisory is not a legally enforceable federal standard, but serves as technical guidance to assist federal, state and local officials.
Median	The middle value of the entire data set for the parameter (range from high to low)
µg/L	microgram per liter or parts per billion
MCL	Maximum Contaminant Level: The highest level of a contaminant allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
MCLG	Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

<b>Median</b>	The middle value of the entire data set for the parameter (range from high to low).
<b>MRDL</b>	Maximum residual disinfectant level: The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
<b>MRDLG</b>	Maximum residual disinfectant level goal: The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
<b>mg/L</b>	milligram per liter or parts per million
<b>NA</b>	Not Applicable
<b>NR</b>	Not Regulated
<b>NTU</b>	Nephelometric Turbidity Unit: A unit to measure turbidity.
<b>pCi/L</b>	Picocuries per Liter: A measure of radioactivity. A picocurie is 10 <sup>-12</sup> curies.
<b>RAA</b>	Running Annual Average: The average of four quarterly samples collected in one 12-month period.
<b>TT</b>	Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water
<b>Trihalomethanes</b>	TTHMs: Chloroform, bromodichloromethane, dibromochloromethane, and bromoform
<b>Turbidity</b>	Turbidity has no health effects. However, turbidity can interfere with disinfection and provide a medium for microbial growth. Turbidity may indicate the presence of disease-causing organisms. These organisms include bacteria, viruses, and parasites that can cause symptoms such as nausea, cramps, diarrhea, and associated headaches. For 2013, the highest value detected or Maximum Value was 0.22 NTU and < 0.3 NTU 100% of the time. For 2015, the highest combined filter effluent Value detected or Maximum Value was 0.21 NTU and < 0.3 NTU 100% of the time.

#### Item 4: Detected Contaminants

The table below shows the regulated contaminants detected in Mequon’s drinking water during 2015. It also includes any detected contaminants found in the recently completed (2013) Unregulated Contaminant Monitoring Rule – Phase 3 (UCMR-3) mandatory monitoring program. **All contaminant levels are within applicable state and federal laws.** The table contains the name of each contaminant, the highest level regulated (Maximum Contaminant Level, or MCL), the ideal goals for public health (Maximum Contaminant Level Goal, or MCLG), the median value detected, the usual sources of such contamination, and footnotes explaining the findings and units of measurement. The presence of a substance in drinking water does not necessarily indicate the water poses a health risk. Certain quantities of some substances are essential to good health, but excessive quantities can be hazardous.

Substance	Ideal Goals (MCLG)	Highest Level Allowed (MCL)	Median Value	Highest Level Detected	Source(s) of Contaminant	Meets Standard
Aluminum	0.2 mg/L	NR	0.046 mg/L	0.117 mg/L	Water treatment additive; Natural deposits	NR
Barium	2 mg/L	2 mg/L	0.018 mg/L	0.018 mg/L	Natural deposits	√
Bromochloroacetic acid	NA	Regulated as a group (HAA5)	< 1 µg/L	2.0 µg/L	Byproduct of drinking water disinfection	√
Bromodichloroacetic acid	NA	Regulated as a group (HAA5)	1.2 µg/L	1.8 µg/L	Byproduct of drinking water disinfection	√
Bromate	10 µg/L	10 µg/L (RAA)	< 3 µg/L (RAA)	5.4 µg/L	Byproduct of drinking water disinfection	√
Bromodichloro-methane	NA	Regulated as a group (TTHMs)	3 µg/L	4 µg/L	Byproduct of drinking water disinfection	√
Chloroform	NA	Regulated as a group (TTHMs)	2 µg/L	3 µg/L	Byproduct of drinking water disinfection	√
Coliform bacteria, Total	Zero	< 5 % of all monthly samples	1	1	Naturally present in the Environment	√
Chlorite	0.8 mg/L	1.0 mg/L	0.002 mg/L	0.0099 mg/L	Byproduct of drinking water disinfection	√
Chlorate**	NA	NR	68 µg/L	195 µg/L	Byproduct of drinking water disinfection	NR
Chlorine, total	4 mg/L	4 mg/L	0.60 mg/L	1.43 mg/L	Residual of drinking water disinfection	√
Chloride	250 mg/L	NR	13.5 mg/L	14.0 mg/L	Natural deposits and road salt	NR

Substance	Ideal Goals (MCLG)	Highest Level Allowed (MCL)	Median Value	Highest Level Detected	Source(s) of Contaminant	Meets Standard
Chromium, Hexavalent**	NA	NR	0.20 µg/L	0.25 µg/L	Natural deposits and manufacturing	NR
Chromium, Total**	NA	100 µg/L	0.3 µg/L	0.3 µg/L	Natural deposits and manufacturing	√
Copper	1.3 mg/L	1.3 mg/L (AL)	0.084 mg/L 90 <sup>th</sup> percentile	0 results above Action Level	Corrosion of household plumbing systems	√
Dibromodichloro-methane	NA	Regulated as a group (TTHMs)	2.0 µg/L	3.0 µg/L	Byproduct of drinking water disinfection	√
Dichloroacetic acid	NA	Regulated as a group (HAA5)	1 µg/L	2.0 µg/L	Byproduct of drinking water disinfection	√
Fluoride	4 mg/L	4 mg/L	0.54 mg/L	0.60 mg/L	Water treatment additive; Natural deposits	√
Gross Alpha particles	Zero	15 pCi/L	1.86 pCi/L	3.42 pCi/L	Natural deposits	√
Gross Beta particles	Zero	50 pCi/L	3.9 pCi/L	4.0 pCi/L	Natural deposits	√
Haloacetic Acids, total	NA	60 µg/L	3 µg/L	4 µg/L	Byproduct of drinking water disinfection	√
Heterotrophic Plate Count Bacteria	NA	TT	Met Requirement	Met Requirement	Naturally present in the environment	√
Iron	0.30 mg/L	NR	0.004 mg/L	0.038 mg/L	Natural deposits	NR
Lead	Zero	15 µg/L (AL)	1.4 µg/L 90 <sup>th</sup> Percentile	0 Results Above Action Level	Corrosion of household plumbing systems	√
Nitrate, as N	10.0 mg/L	10.0 mg/L	0.30 mg/L	0.30 mg/L	Natural deposits and farm runoff	√
Molybdenum**	NA	NR	1.0 µg/L	1.1 µg/L	Natural deposits	NR
pH	NA	6.5 to 8.5	7.63	7.88	Naturally present in the environment	√
Perchlorate (UCMR -1 Contaminant)	NA	Regulation Pending	0.10 µg/L	0.10 µg/L	Byproduct of drinking water disinfection	NR
Radium, combined <sup>226 + 228</sup>	Zero	5 pCi/L	1.20 pCi/L	1.51 pCi/L	Natural deposits	√
Strontium**	NA	NR	120 µg/L	120 µg/L	Natural deposits	NR
Sulfate	500 mg/L	NR	28.7 mg/L	32.8 mg/L	Natural deposits	NR
Trihalomethanes, total	NA	80 µg/L	11 µg/L	11.2 µg/L	Byproduct of drinking water disinfection	√
Total Dissolved Solids	500	NR	179 mg/L	206 mg/L	Natural deposits	NR
Trichloroacetic acid	NA	Regulated as a group (HAA5)	< 0.5 µg/L	1.0 µg/L	Byproduct of drinking water disinfection	√
Turbidity	NA	<0.3 NTU 95% of the time	0.03 NTU 95% of the time	0.21 NTU 1-day max	Natural deposits	√
Uranium, total	Zero	30 µg/L	0.23 µg/L	0.25 µg/L	Natural deposits	√
Vanadium**	NA	NR	0.3 µg/L	0.3 µg/L	Natural deposits	NR

\*\*Data from 2013, the most recent UCMR sampling period.

3

**Item 5: Information on monitoring for *Cryptosporidium*, Radon, and Other Contaminants (if detected)**

*Cryptosporidium* was detected in any of 24 source water samples during 2015. There were no detections of *Cryptosporidium* in the finished water in 2015.

Mequon’s water supplier, The Milwaukee Water Works, is recognized as a national leader in providing safe, high-quality drinking water that complies with all state and federal drinking water standards. In addition, MWW is known for its extensive water quality monitoring program that goes well above and beyond basic requirements. This monitoring and screening program includes organisms and substances that are not yet regulated, but considered of emerging concern and/or under study for possible effects on public health.

The table below shows the unregulated substances detected in Milwaukee’s drinking water during 2015. **There is no known adverse health effect from these substances in drinking water at these levels.** The complete list of over 500 substances tested for can be found at [www.milwaukee.gov/water/about/WaterQuality.htm](http://www.milwaukee.gov/water/about/WaterQuality.htm).

Substance	Range of Values Detected
Aldehydes, Total	<0.5 – 7.2 µg/L
Ammonia <sup>1</sup> , as N	0.33 – 0.54 µg/L
Boron <sup>2</sup>	0.025 µg/L
Bromide	0.017 – 0.041 mg/L
Bromochloroacetonitrile	0.5 – 1.0 µg/L
Calcium	34 mg/L
Chloropicrin	<0.5 – 1.4 µg/L
Dibromoacetonitrile	< 0.7-1.3 µg/L
Dichloroacetonitrile	< 0.5-0.9 µg/L
Dichloropropanone	< 0.5-0.5 µg/L
Erucylamide	6.8 µg/L
Isophorone <sup>3</sup>	0.12 µg/L
Lithium	2.3 µg/L
Magnesium	12 mg/L
Magnesium Hardness	43-60 mg/L
Gallium	0.001 mg/L
Phosphate, as PO4	1.82-2.39 mg/L
Potassium	1.4-1.7 mg/L
Rubidium	1.1 µg/L
Silica	1.95-2.0 mg/L
Sodium	9.5 – 14.4 mg/L
Total Organic Carbon	1.2 – 1.4 mg/L
Trichloropropanone	< 0.5 – 0.6 µg/L

<sup>1</sup>Ammonia has a lifetime HA of 30 mg/L

<sup>2</sup>Boron has a lifetime HA of 6 mg/L

<sup>3</sup>Isophorone has a lifetime HA of 100 µg /L

#### Item 6: Compliance with Other Drinking Water Regulations

The Milwaukee Water Works had one monitoring violation, or Notice of Non-Compliance, of the Safe Drinking Water Act in 2015; the First QTR Disinfection By-Products compliance monitoring samples were collected on day early, outside the designated compliance sample collection window. A Tier 3 Public Notification was issued on September 5, 2015.

## **Item 7: Variances and Exemptions (not applicable)**

### **Item 8: Required Educational Information**

As water flows through rivers and lakes and over land surfaces, naturally occurring substances may be dissolved in the water that reaches Lake Michigan. These substances are referred to as contaminants. Surface water sources may be highly susceptible to contaminants. Surface water is also affected by animal and human activities. Read the DNR Source Water Assessment for Milwaukee at [milwaukee.gov/water/WaterQuality](http://milwaukee.gov/water/WaterQuality). Contaminants that may be present in source water include microbial contaminants such as viruses, protozoa and bacteria; inorganic contaminants such as salts and metals, pesticides and herbicides, organic chemical contaminants, and radioactive contaminants.

To ensure that tap water is safe to drink, the EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline, 800-426-4791. The table of contaminants detected by the Mequon Water Utility and its water supplier is on pages 2-3 of this report.

#### **Health Precautions**

Some people may be more vulnerable to contaminants in drinking water than the general population. Immunocompromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking tap water from their health care providers. EPA/CDC (Centers for Disease Control) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Environmental Protection Agency's Safe Drinking Water Hotline at 800-426-4791, and the CDC at [cdc.gov/parasites/crypto](http://cdc.gov/parasites/crypto).

#### ***Cryptosporidium***

*Cryptosporidium* is a microscopic protozoan that when ingested, can result in diarrhea, fever, and other gastrointestinal symptoms. The organism is found in many surface water sources (lakes, rivers, streams) and comes from human and animal wastes in the watershed. The risk of *Cryptosporidium* from drinking water in Mequon is extremely low due to an effective treatment combination implemented by our supplier.

The Milwaukee Water Works provides a brochure based on EPA and CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium*. Obtain a copy at [milwaukee.gov/water/about/WaterQuality.htm](http://milwaukee.gov/water/about/WaterQuality.htm); scroll down to Resource Links, choose "Information for Persons with High Risk Immune Systems."

#### **Lead and Copper**

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Mequon Water Utility is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to two minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the EPA Safe Drinking Water Hotline, 1-800-426-4791, or at [epa.gov/safewater/lead](http://epa.gov/safewater/lead).

**Notice to Parents of Infants Six Months of Age or Younger**

*According to the CDC, the proper amount of fluoride from infancy and at all ages throughout life helps prevent and control tooth decay (cavities). Therefore, the Milwaukee Water Works, following public health recommendations, maintains a level of fluoride in our drinking water that is both safe and effective. Per Common Council File No. 120187 adopted on July 24, 2012, we are required to include the following advisory regarding fluoride and young infant in our annual water quality reports and on our website.*

The American Academy of Pediatrics recommends exclusive breastfeeding for the first six months of a child's life, followed by continued breastfeeding as complementary foods are introduced, for optimal short- and long-term health advantages. Go to <<http://pediatrics.aappublications.org/content/129/3/e827.full>> for more information.

As of August 31, 2012, Mequon Water Utility water is fluoridated at a level not to exceed 0.7 mg/L. According to the CDC, for infants up to six months of age, if tap water is fluoridated or has substantial natural fluoride (0.7 mg/L or higher) and is being used to dilute infant formula, a parent may consider using a low-fluoride alternative water source. Bottled water known to be low in fluoride is labeled as purified, deionized, demineralized, distilled, or prepared by reverse osmosis. Ready-to-feed (no-mix) infant formula typically has little fluoride and may be preferable at least some of the time. If breastfeeding is not possible, parents should consult a pediatrician about an appropriate infant formula option. Parents should be aware that there may be an increased chance of mild dental fluorosis if the child is exclusively consuming infant formula reconstituted with fluoridated water. Dental fluorosis is a term that covers a range of visible changes to the enamel surface of the tooth. Go to <[http://www.cdc.gov/fluoridation/safety/infant\\_formula.htm](http://www.cdc.gov/fluoridation/safety/infant_formula.htm)> for more information on dental fluorosis and the use of fluoridated drinking water in infant formula.

4/4/16